

ANNEXURE-C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 154

Dated 01-01-2026

It is certified that an inspection team headed by Dr. Amit Sagar Medical officer (Name of Officers with designation) from CHC Saraswati Nagar (Sawra) PHED inspected the D.A.V. Sr. Sec. PUBLIC SCHOOL, SARASWATI-NAGAR (SAWRA), P.O. HATKOTI, TEHSIL JUBBAL, DISTT. SHIMLA (HP) (Name & Address of the School) on 31-12-2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing No. N/C- dated 01-10-2025 of Water testip laboratory Jubbal (PHED Lab) certified that the D.A.V. Sr. Sec. PUBLIC SCHOOL, SARASWATI-NAGAR (SAWRA), P.O. HATKOTI, TEHSIL JUBBAL, DISTT. SHIMLA (HP) (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central/State/U.T. Govt.

This certificate is valid to 01-01-2026 to 31-12-2026

Signature with Seal

Name

Designation

Name & Address of the Office/Department

To

THE PRINCIPAL,
DAV Sr. Sec. PUBLIC SCHOOL,
SARASWATI-NAGAR (SAWRA)
P.O. HATKOTI, TEHSIL JUBBAL, DISTT. SHIMLA (HP).

Note : The certificate is to be issued by authorised officer/PED Lab/Local bodies.

WATER TESTING LABORATORY, JUBBAL
JAL JEEVAN MISSION JUBBAL, PHASE 1 (A.P.)-72600 (Test Address only)

Test report

Sample ID:

UTW11553224648

User Information

Name: Jee Swara Mobile: 943082226
 Email: jee@jbbal@gmail.com Pin Code: 0
 Full Address: Village: Not available, Gram Panchayat: Not available, Block: Not available, District: Sharda, State: Himachal Pradesh

Sample description

Source of Sample: Location: (in Habit/Urban / Source type: River / [scheme/60 / 72400], scheme name / PWD/LWS) Village: HATROH
 Gram Panchayat: Sarra (Ganswal Nagar) Block: JUBBAL
 District: Sharda State: Himachal Pradesh
 Address: Remarks:
 Latitude: 31.0 Longitude: 77.2

Date & time of sample collection	Date & time of sample received in lab	Date & time of sample analysed	Date & time of report generation
30.09.2025 07:20:00 AM	30.09.2025 11:05:00 AM	01.10.2025 11:20:00 AM	01.10.2025 01:00:50 PM

Test results

S. No.	Parameters tested	Unit of measurement	Regulatory (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Method of Analysis	Remarks
1	Calcium (as Ca)*	mg/l	75	200	35.000	EDTA Titrimetric method	
2	Chloride (as Cl)*	mg/l	250	1000	28.400	Argentometric method	
3	Colour*	Kazen units	5	15	5.000	Visual comparison method	
4	Free residual Chlorine	mg/l	0.2	1	0.000	Titrimetric method	
5	Magnesium (As Mg)*	mg/l	30	100	2.430	Calculation by APHA	
6	pH*	NA	6.5-8.5	No Relaxation	8.800	Electrometric method	
7	TDS*	mg/l	500	2000	53.000	Instrumental method	
8	Temperature	NA	NA	NA	12.000	Instrumental method	
9	Total Alkalinity (as Calcium Carbonate)*	mg/l	200	600	50.000	Titration method	
10	Total Hardness (As CaCO ₃)*	mg/l	200	600	45.000	EDTA Titrimetric method	
11	Turbidity*	NTU	1	5	0.000	Nephelometric method	

- Note:
- 1) *Indicates parameters that are NABL accredited.
 - 2) This test results related to the sample tested above.
 - 3) The report shall not to be reproduced in full without approval of authority.
 - 4) This is the end of the report.

Data prepared by
 Chemist (MMS-12402)

Authorised signatory
 Sh. Yash Pal Sharma (Test Lab In-charge)

*****This is an electronically generated report and does not require a signature.*****

Jal Jeevan Mission aims at potable tap water supply to every home
 Let's join hands to ensure drinking water is potable, it helps in preventing water borne diseases and improve public health.